

North Smithfield Fire Prevention

PUMPKIN FEST FIRE SAFETY

All vendor's booths, tents, propane tanks, portable generators, charcoal grills, electrical equipment, appliances, fire extinguishers or any other festival structures or equipment shall be subject to inspection by the Fire Marshal prior to the start of or anytime during the event.

- 1. No cooking within 10' of a canopy**
- 2. Keep extra fuel/propane away from cooking area**
- 3. Keep young children away from the hot cooking area**
- 4. Be mindful of trip hazards around your area (power cords, boxes, supplies, etc.)**
- 5. Use electrical power that is supplied for you**
- 6. All cords shall be free of splices, cuts or breaks in outer sheathing.**
- 7. UL or other approved Strip Plugs with integral circuit breaker are the only allowed power tap/adaptor**
- 8. An approved 5lb. ABC fire extinguisher with a minimum rating of 2A 10BC. (or approved by the Fire Marshal)**
- 9. Booths with deep fat fryers also require a Class "K" rated fire extinguisher.**
- 10. Hood suppression systems MUST have current annual inspection documentation.**
- 11. Keep fire extinguishers accessible and conspicuous.**
- 12. No flammable liquids will be allowed into an area where open flames exist.**
- 13. All tanks/cylinders (whether in use or storage) must be secured to avoid falling and damaging the valve assembly**
- 14. Store tanks/cylinders upright so pressure relief valve is in vapor space.**
- 15. All combustibles shall be kept 3 feet away from heat sources.**
- 16. No cooking appliances/heat sources will be within physical reach of the general public**

ALL VENDORS SHOULD BE AWARE THAT THE FIRE MARSHAL WILL INSPECT THE SITE PRIOR TO THE OPENING OF THE FESTIVAL/EVENT AND THAT ALL OF THE ITEMS CONTAINED HEREIN ARE THE RESPONSIBILITY OF THE VENDOR AND MUST BE IN PLACE OR THE VENDOR WILL NOT BE ALLOWED TO OPEN FOR BUSINESS. IF DURING THE COURSE OF THE EVENT AN ONSITE INSPECTION DETERMINES THAT THERE IS A VIOLATION OF ANY OF THESE CONDITIONS, THE VENDOR'S BUSINESS SHALL BE CLOSED UNTIL SUCH TIME AS THE PROPER CORRECTIVE MEASURES HAVE BEEN TAKEN AND INSPECTED BY THE FIRE MARSHAL OR DESIGNEE.

Lt. David Mowry

North Smithfield Fire & Rescue Service Inc.

Fire Marshal/IAAI-FIT